Garden State Laboratories, Inc.

Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 360616010.0
CLIENT # GAT15
DATE SUBMITTED: 6/16/16

TO: Gateway School
2210 West County Line Road

Jackson NJ 08527
ATT: Mark Costa

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: TAG #238254
SAMPLE LOCATION: BASEMENT FILTER - GATEWAY SCHOOL, 60 HIGH STREET, CARTERET, NEW JERSEY, 07008

DATE SAMPLED: 6/15/16 TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	6/20/16

< = less than, not detected.
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

297514

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 360616011.0
CLIENT # GAT15
DATE SUBMITTED: 6/16/16

TO: Gateway School
2210 West County Line Road

Jackson NJ 08527
ATT: Mark Costa

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: TAG #238256
SAMPLE LOCATION: ADL ROOM - GATEWAY SCHOOL, 60 HIGH STREET, CARTERET, NEW JERSEY, 07008

DATE SAMPLED: 6/15/16 TIME SAMPLED: 07:21

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	6/20/16

< = less than, not detected.
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

297514

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 360616012.0
CLIENT # GAT15
DATE SUBMITTED: 6/16/16

TO: Gateway School
2210 West County Line Road

Jackson NJ 08527
ATT: Mark Costa

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: TAG #238269
SAMPLE LOCATION: 1ST FLOOR WATER FOUNTAIN - GATEWAY SCHOOL, 60 HIGH STREET, CARTERET, NEW JERSEY, 07008

DATE SAMPLED: 6/15/16 TIME SAMPLED: 07:23

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	6/20/16

< = less than, not detected.
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

297514

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com
Internet: www.gslabs.com

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF ANALYSIS

REPORT # 360616013.0
CLIENT # GAT15
DATE SUBMITTED: 6/16/16

TO: Gateway School
2210 West County Line Road

Jackson NJ 08527
ATT: Mark Costa

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID: TAG #238270
SAMPLE LOCATION: 2ND FLOOR WATER FOUNTAIN - GATEWAY SCHOOL, 60 HIGH STREET, CARTERET, NEW JERSEY, 07008

DATE SAMPLED: 6/15/16 TIME SAMPLED: 07:25

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	6/20/16

< = less than, not detected.
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

297514

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.